



中国认可
检测
TESTING
CNAS L0738

170021131268



CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CCRI 18.2200X

Company: Shanghai Rocksensor Automation Co.,Ltd.
Address: No.118 Lane315 Yuanqu Bei Road, North 2/F Bldg.3, Minhang, Shanghai
Name of Product: Multiparameter flow transmitter
Type of Product: RP1005
Marking: Ex ia II C T6 Ga
Technical Documents: Q/LDS 002-2018
Drawing No.: RP1005-000
Note(s):

1. Rated voltage 24VDC, Intrinsic Parameter: Ui:28VDC, Ii:93mA, Ci:0.03μF, Li:0mH,Pi:0.65W;
2. IP code:IP66;
3. The suffix "X" indicates that the product should avoid an ignition hazard due to impact or friction.

By verifying the drawings and technical documents and checking samples,the product complies with the following standars currently valid in P.R.China:

GB 3836.1-2010 , GB 3836.4-2010, GB/T 4208-2017

Date of Issue: 10.9.2018

Valid till: 10.8.2023

Authorize:



China Coal Research Institute Testing Center

(The test center of the national safety production of mining equipment and mining oil in Beijing)

Note: This certificate is only valid for the products that are in accord with samples tested and verified.

Center Add: No.5 Qingniangou Road,Hepingli,Beijing,100013

Tel/fax: 010-84262992

The query url of Explosion-proof Certificate: <http://www.ccrirc.com.cn/Home>